



Test Verification of Conformity

Verification Number: 220321044GZU-VOC001

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant  mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Shenzhen SOFARSOLAR Co., Ltd. 11/F., Gaoxinqi Technology Building, No.67 Area, Xingdong Community, Xin'an Sub-district, Bao'an District, Shenzhen City, China
Product Description:	Intelligent Residential System
Models/Type References:	For Inverter Module: ESI 3K-S1, ESI 3.68K-S1, ESI 4K-S1, ESI 4.6K-S1, ESI 5K-S1, ESI 5K-S1-A, ESI 6K-S1 For Energy Storage Battery: BTS 5K
Ratings & Principle Characteristics:	See Appendix
Brand Name:	
Relevant Standards/Directives:	EN IEC 61000-6-3:2021 EN IEC 61000-6-1:2019 EMC Directive 2014/30/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China
Date of Tests:	23 September 2022 to 27 September 2022
Test Report Number(s):	220321044GZU-001

Additional information in Appendix.



Signature

Name: Sky Zhu
Position: Team Leader
Date: 05 December 2022

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 220321044GZU-VOC001

Ratings & Principle
Characteristics for Inverter
Module

MODEL	ESI 3K-S1	ESI 3.68K-S1	ESI 4K-S1	ESI 4.6K-S1
Max.DC input voltage	550Vdc			
MPPT voltage range	85~520Vdc			
Max.PV Isc	2*22.5A			
Rated battery voltage	400V			
Max.charging/discharging current	20A			
Max.charging/discharging power	3000W	3680W	4000W	4600W
Rated grid voltage	230V,50Hz			
Rated output voltage	230V,50/60Hz			
Max.output current	15A	16A	20A	20.9A
Power Factor	1 default (adjustable+/-0.8)			
Rated output power	3000W	3680W	4000W	4600W
Backup Rated Current	13A	16A	17.4A	20A
Backup Rated Apparent Power	3000VA	3680VA	4000VA	4600VA
Ambient Temperature	-10~ +50°C			
Protection Degree	IP65			
Protection Class	Class I			
Inverter topology	Non-Isolated			
Overvoltage Category	AC III, DC II			
Firmware version:	V000001			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

MODEL	ESI 5K-S1	ESI 5K-S1-A	ESI 6K-S1
Max.DC input voltage	550Vdc		
MPPT voltage range	85~520Vdc		
Max.PV Isc	2*22.5A		
Rated battery voltage	400V		
Max.charging/discharging current	20A		
Max.charging/discharging power	5000W	5000W	6000W
Rated grid voltage	230V,50Hz		
Rated output voltage	230V,50/60Hz		
Max.output current	25A	22.7A	30A
Power Factor	1 default (adjustable+/-0.8)		
Rated output power	5000W	5000W	6000W
Backup Rated Current	21.7A	22.7A	26A
Backup Rated Apparent Power	5000VA	5000VA	6000VA
Ambient Temperature	-10~ +50℃		
Protection Degree	IP65		
Protection Class	Class I		
Inverter topology	Non-Isolated		
Overvoltage Category	AC III, DC II		
Firmware version:	V000001		

Ratings & Principle
Characteristics for Energy
Storage Battery

MODEL	BTS 5K
Battery Type	LFP
Battery Interface	Isolated
Total Energy	5120Wh
Max Output Current	7.5A
Weight	50Kg
Input/Output	300-435Vdc, 7.5A, 2.5kW
Operating Temperature Range	-10 ~ +50℃

Signature



Name: Sky Zhu

Position: Team Leader

Date: 05 December 2022

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.