

## ATTESTATION of conformity with European Directives

Attestation Number: Product:	2088AB0511N080002 Solar Grid-tied Inverter	
Brand Name:	SEAR	
Model:	SOFAR 24KTLX-G3, SOFAR 15KTLX-G3	
Additional Model:	SOFAR 17KTLX-G3, SOFAR 20KTLX-G3, SOFAR 22KTLX-G3	
Applicant:	Shenzhen SOFARSOLAR Co., Ltd.	
Address:	401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China.	
Technical Characteristics:	Max. DC Input Voltage: DC 1100V Operating MPPT Voltage Range: DC 140~1000V Max. Input Current: 26A/26A Nominal Grid Voltage: AC 380/400V Nominal Grid Frequency: 50/60Hz	

The submitted sample of the above equipment has been tested according to following standards:

Standards	Report Number	Report date
IEC 61000-6-3:2006 + A1:2010	C200511N080	Dec. 10, 2020
IEC 61000-3-11:2017		
IEC 61000-3-12:2011		
IEC 61000-6-1:2016		

Assistant Manager EMC Department

Name: Glyn He Date: Dec. 10, 2020

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd.

Information given in this document is related to the tested specimen of the described electrical sample.

Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch No. 96, Guantai Road (Houjie Section), Houjie Town, Dongguan City, Guangdong Province. 523942. People's Republic of China.

Tel.: +86 769 8998 2098 Fax: +86 769 8593 1080 Email:<u>customerservice.dg@cn.bureauveritas.com</u>